# **SECTION 260535**

#### SURFACE RACEWAYS

### PART 1 GENERAL

# 1.1 SECTION INCLUDES

- A. Surface metal raceways.
- B. Multi-outlet assemblies.
- C. Wireways.
- D. Wall duct.

#### 1.2 RELATED SECTIONS

- A. Section 26 05 39 Underfloor Ducts: Trench duct.
- B. Section 26 27 26 Wiring Devices: Receptacles.

# 1.3 REFERENCES

- A. NECA (National Electrical Contractors Association) Standard of Installation.
- B. NEMA WD 6 Wiring Device Configurations.

#### 1.4 SUBMITTALS

- A. Submit under the provisions of Division 01.
- B. Product Data: Provide dimensions, knockout sizes and locations, materials, fabrication details, finishes, and accessories.
- C. Manufacturer's Instructions: Indicate application conditions and limitations of use stipulated by Product testing agency specified under Regulatory Requirements. Include instructions for storage, handling, protection, examination, preparation, and installation of Product.

## 1.5 QUALITY ASSURANCE

A. Perform Work in accordance with NECA Standard of Installation.

## 1.6 REGULATORY REQUIREMENTS

- A. Conform to requirements of ANSI/NFPA 70.
- B. Furnish products listed and classified by testing firm acceptable to authority having jurisdiction as suitable for purpose specified and shown.

#### PART 2 PRODUCTS

# 2.1 SURFACE METAL RACEWAY

- A. Manufacturers:
  - 1. Wiremold Model 500 for power or data only. Model 2400D dual channel for both power and data.
  - 2. Substitutions: Under provisions of Division 01.
- B. Description: Sheet metal channel with fitted cover, suitable for use as surface metal raceway.
- C. Finish: Paint to match adjacent surfaces.
- D. Fittings, Boxes, and Extension Rings: Furnish manufacturer's standard accessories.

## PART 3 EXECUTION

# 3.1 INSTALLATION

- A. Install Products in accordance with the manufacturer's instructions.
- B. Use flat-head screws, clips, and straps to fasten raceway channel to surfaces. Mount plumb and level.
- C. Use suitable insulating bushings and inserts at connections to outlets and corner fittings.
- D. Wireway Supports: Provide steel channel as specified in Section 26 05 29.
- E. Close ends of wireway and unused conduit openings.
- F. Ground and bond raceway under the provisions of Section 26 05 26.

**END OF SECTION**